

City of Pflugerville - PWSID #2270014



Backflow Prevention Assembly Test and Maintenance Report

The following form must be completed for each assembly tested. A signed and dated original must be submitted to the public water supplier for record keeping *purposes

Customer Information

Customer / Property Name: **Resident**
Contact Name: **N/A**
Property Address: **1700 Winding Talley Street
Pflugerville, TX 78660**

PWS Information

PWS Contact Name: **Oswaldo Merino (Tito)**
PWS Phone Number: **512-990-6436**
PWS Address: **15500 Sun Light Near Way #B
Pflugerville, TX, 78691**

The backflow prevention assembly detailed below has been tested as required by TCEQ regulations and is certified to be operating within acceptable parameters.

Assembly Information

Type: **DC**
Size: **1"**
Manufacturer: **Apollo**
Location: **Right front yard 5 feet from meter**
Reason for test: [] new [X] existing [] replaced.

Model #: **DC4A**
Serial#: **85353C**
BPA Serves: **Irrigation**

PASS

Test Date: 2024-12-11

Is the assembly installed in accordance with manufacturer recommendations and/or local codes? [X] yes [] no

Water supply: Potable

Assembly Test Information

Initial Test (Time: 04:30 pm)	
Check Valve #1 : 2.2 (X) Closed Tight/Held () Leaked	Check Valve #2 : 1.9 (X) Closed Tight/Held () Leaked
Final Test	
Check Valve #1 : 2.2 (X) Closed Tight/Held () Leaked	Check Valve #2 : 1.9 (X) Closed Tight/Held () Leaked

As the tester of record, I affirm this test as: Passed [X] Failed [] **Repairs Made:** No**

Additional comments or repairs made / materials (parts) used:

(no comments)

Tester Information

Tester Name: **Weyant, Brad**
Tester License Expiration: **12-03-2027**
Certification#: **BP0016935**
Test Kit Serial #: **09231317**
Test Kit Date Tested for Accuracy: **03-14-2024**
Test Kit Mfr. & Mod. #: **Mid-West 845-5 (Potable)**
Testing Co Name: **Safewater Backflow and Irrigation**
Phone: **(512) 605-9790**
Address: **PO Box 4002
Austin, TX 78765**

The above tester certifies that all information submitted for this report is true and accurate

* TEST RECORDS MUST BE KEPT FOR AT LEAST THREE YEARS [30 TAC §290.46(B)]

** USE ONLY MANUFACTURER'S REPLACEMENT PARTS

The backflow prevention assembly detailed above has been tested and maintained as required by commission regulations and is certified to be operating within acceptable parameters