

City of Leander - PWSID #2460012



Backflow Prevention Assembly Test and Maintenance Report

The following form must be completed for each assembly tested. A signed and dated original must be submitted to the public water supplier for record keeping *purposes

Customer Information

Customer / Property Name: **Resident**
Contact Name: **N/A**
Property Address: **1712 Martin Wells St
Leander, TX 78641-5775**

PWS Information

PWS Contact Name: **Jeff Tucker**
PWS Phone Number: **(512) 528-2780**
PWS Address: **PO Box 319
Leander, TX, 78646**

The backflow prevention assembly detailed below has been tested as required by TCEQ regulations and is certified to be operating within acceptable parameters.

Assembly Information

Type: **DC** Model #: **DC4A**
Size: **1"** Serial#: **98113C**
Manufacturer: **Apollo** BPA Serves: **Irrigation**
Location: **4" N of Water Meter**
Reason for test: [] new [X] existing [] replaced.
Is the assembly installed in accordance with manufacturer recommendations and/or local codes? [X] yes [] no
Water supply: Potable

PASS

Test Date: 2024-10-09

Assembly Test Information

Initial Test (Time: 01:15 pm)	
Check Valve #1 : 1.8 (X) Closed Tight/Held () Leaked	Check Valve #2 : 1.9 (X) Closed Tight/Held () Leaked
Final Test	
Check Valve #1 : 1.8 (X) Closed Tight/Held () Leaked	Check Valve #2 : 1.9 (X) Closed Tight/Held () Leaked

As the tester of record, I affirm this test as: Passed [X] Failed [] **Repairs Made:** No**

Additional comments or repairs made / materials (parts) used:
(no comments)

Tester Information

Tester Name: **Sinclair, Lewis**
Tester License Expiration: **02-12-2026**
Certification#: **BP0002815**
Test Kit Serial #: **10200408**
Test Kit Date Tested for Accuracy: **02-28-2024**
Test Kit Mfr. & Mod. #: **Mid-West 845-5 (Potable)**
Testing Co Name: **L Sinclair Services Inc.**
Phone: **(512) 563-8762**
Address: **1307 Machado Road
Cedar Park, TX 78613**

The above tester certifies that all information submitted for this report is true and accurate
* TEST RECORDS MUST BE KEPT FOR AT LEAST THREE YEARS [30 TAC §290.46(B)]
** USE ONLY MANUFACTURER'S REPLACEMENT PARTS

The backflow prevention assembly detailed above has been tested and maintained as required by commission regulations and is certified to be operating within acceptable parameters