

BACKFLOW PREVENTION ASSEMBLY TEST AND MAINTENANCE REPORT

The following form must be completed for each assembly tested. A signed and dated original must be submitted to the public water supplier for recordkeeping *purposes:

NAME OF PWS:	Travis County MUD 2
PWS ID#:	2270403
PWS MAILING ADDRESS:	1502 San Juan Dr. Austin, TX 78733
PWS CONTACT PERSON:	Backflow Reports
ADDRESS OF SERVICE:	17716 Chamoix Drive Austin, TX 78738

The backflow prevention assembly detailed below has been tested and maintained as required by commission regulations and is certified to be operating within acceptable parameters.

TYPE OF BACKFLOW PREVENTION ASSEMBLY (BPA):

<input type="checkbox"/>	Reduced Pressure Principle (RPBA)	<input type="checkbox"/>	Reduced Pressure Principle-Detector (RPBA-D)	Type II	<input type="checkbox"/>
<input checked="" type="checkbox"/>	Double Check Valve (DCVA)	<input type="checkbox"/>	Double Check-Detector (DCVA-D)	Type II	<input type="checkbox"/>
<input type="checkbox"/>	Pressure Vacuum Breaker (PVB)	<input type="checkbox"/>	Spill-Resistant Pressure Vacuum Breaker (SVB)		

Manufacturer:	Main: Apollo	Bypass:	Size:	Main: 1"	Bypass:
Model Number:	Main: DC4A	Bypass:	BPA Location:	Left front yard 10 ft from meter	
Serial Number:	Main: 97811C	Bypass:	BPA Serves:	Irrigation	


Reason for test:	New <input checked="" type="checkbox"/>	Existing <input type="checkbox"/>	Replacement <input type="checkbox"/>	Old Model/Serial #	
Is the assembly installed in accordance with manufacturer recommendations and/or local codes?					<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
Is the assembly installed on a non-potable water supply (auxiliary)?					<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No

TEST RESULT	Reduced Pressure Principle Assembly (RPBA)		Type II Assembly	PVB & SVB		
	DCVA		Relief Valve	Bypass Check	Air Inlet	Check Valve
	1 st Check	2 nd Check***				
PASS <input checked="" type="checkbox"/>						
FAIL <input type="checkbox"/>						
Initial Test	Held at <u>1.8</u> psid	Held at <u>2.3</u> psid	Opened at <u> </u> psid	Held at <u> </u> psid	Opened at <u> </u> psid	Held at <u> </u> psid
Date: 11/5/2024	psid	Closed Tight <input checked="" type="checkbox"/>	psid	Closed Tight <input type="checkbox"/>	Did not open <input type="checkbox"/>	psid
Time: 12:20PM	Closed Tight <input checked="" type="checkbox"/>	Leaked <input type="checkbox"/>	Did not open <input type="checkbox"/>	Leaked <input type="checkbox"/>	Did it fully open (Yes <input type="checkbox"/> /No <input type="checkbox"/>)	Leaked <input type="checkbox"/>
	Leaked <input type="checkbox"/>		open <input type="checkbox"/>			
Repairs and Materials Used**	Main: <u> </u> Bypass: <u> </u>					
Test After Repair	Held at <u> </u> psid	Held at <u> </u> psid	Opened at <u> </u> psid	Held at <u> </u> psid	Opened at <u> </u> psid	Held at <u> </u> psid
Date:	Closed Tight <input type="checkbox"/>	Closed Tight <input type="checkbox"/>	psid	Closed Tight <input type="checkbox"/>		psid
Time:				Tight <input type="checkbox"/>		

*** 2nd check: numeric reading required for DCVA only

Differential pressure gauge used:	Potable: <input checked="" type="checkbox"/>	Non-Potable: <input type="checkbox"/>
Make/Model: MidWest 845	SN: 09231317	Date tested for accuracy: 3/14/2024

Remarks:	

Company Name:	Safewater Backflow	Licensed Tester Name (Print/Type):	Brad Weyant
Company Address:	PO Box 4002 Austin, TX 78765	Licensed Tester Name (Signature):	
Company Phone #:	512-605-9790	BPAT License #	BP0016935
		License Expiration Date:	12/3/2024

The above is certified to be true at the time of testing.

* TEST RECORDS MUST BE KEPT FOR AT LEAST THREE YEARS [30 TAC §290.46(B)]

** USE ONLY MANUFACTURER'S REPLACEMENT PARTS