City of Leander - PWSID #2460012

Backflow Prevention Assembly Test and Maintenance Report

The following form must be completed for each assembly tested. A signed and dated original must be submitted to the public water supplier for record keeping *purposes

Customer Information		PWS Information	
Customer / Property Name:	Resident	PWS Contact Name:	Jeff Tucker
Contact Name:	N/A	PWS Phone Number:	(512) 528-2780
Property Address:	1824 Arenzano Pl	PWS Address:	PO Box 319
	Leander, TX 78641-6085		Leander, TX, 78646

The backflow prevention assembly detailed below has been tested as required by TCEQ regulations and is certified to be operating within acceptable parameters.

Assembly Information

	Туре:	DC	Model #:	DC4A	PASS
	Size:	1"	Serial#:	53285C	
	Manufacturer:	Apollo	BPA Serves:	Irrigation	
	Location:	Left front yard 10 feet from meter			Test Date: 2024-07-23
Reason for test: [X] new [] existing [] replaced.					

Is the assembly installed in accordance with manufacturer recommendations and/or local codes? [X] yes [] no Water supply: Potable

Assembly Test Information

Check Valve #2 : 1.7		
(X) Closed Tight/Held() Leaked		
Final Test		
Check Valve #2 : 1.7		
(X) Closed Tight/Held() Leaked		

As the tester of record, I affirm this test as: Passed [X] Failed [] Repairs Made:** No

Additional comments or repairs made / materials (parts) used:

(no comments)

Tester Information	
Tester Name:	Weyant, Brad
Tester License Expiration:	12-03-2024
Certification#:	BP0016935
Test Kit Serial #:	09231317
Test Kit Date Tested for Accuracy:	03-14-2024
Test Kit Mfr. & Mod. #:	Mid-West 845-5 (Potable)
Testing Co Name:	Safewater Backflow and Irrigation
Phone:	(512) 605-9790
Address:	PO Box 4002
	Austin, TX 78765

The above tester certifies that all information submitted for this report is true and accurate

* TEST RECORDS MUST BE KEPT FOR AT LEAST THREE YEARS [30 TAC §290.46(B)]

** USE ONLY MANUFACTURER'S REPLACEMENT PARTS

The backflow prevention assembly detailed above has been tested and maintained as required by commission regulations and is certified to be operating within acceptable parameters

