

# City of Leander - PWSID #2460012



## Backflow Prevention Assembly Test and Maintenance Report

The following form must be completed for each assembly tested. A signed and dated original must be submitted to the public water supplier for record keeping \*purposes

### Customer Information

Customer / Property Name: **Resident**  
Contact Name: **N/A**  
Property Address: **1825 Vercellina Vw  
Leander, TX 78641-3861**

### PWS Information

PWS Contact Name: **Jeff Tucker**  
PWS Phone Number: **(512) 528-2780**  
PWS Address: **PO Box 319  
Leander, TX, 78646**

The backflow prevention assembly detailed below has been tested as required by TCEQ regulations and is certified to be operating within acceptable parameters.

### Assembly Information

Type: **DC** Model #: **DC4A**  
Size: **1"** Serial#: **01485D**  
Manufacturer: **Apollo** BPA Serves: **Irrigation**  
Location: **7' SW of Water Meter**  
Reason for test: [ ] new [X] existing [ ] replaced.  
Is the assembly installed in accordance with manufacturer recommendations and/or local codes? [X] yes [ ] no  
Water supply: Potable

# PASS

Test Date: 2024-10-23

## Assembly Test Information

Initial Test ( Time: 02:55 pm )	
Check Valve #1 : 2.1 (X) Closed Tight/Held ( ) Leaked	Check Valve #2 : 1.8 (X) Closed Tight/Held ( ) Leaked
Final Test	
Check Valve #1 : 2.1 (X) Closed Tight/Held ( ) Leaked	Check Valve #2 : 1.8 (X) Closed Tight/Held ( ) Leaked

As the tester of record, I affirm this test as: Passed [X] Failed [ ] **Repairs Made:\*\* No**

Additional comments or repairs made / materials (parts) used:

**( no comments )**

### Tester Information

Tester Name: **Sinclair, Lewis**  
Tester License Expiration: **02-12-2026**  
Certification#: **BP0002815**  
Test Kit Serial #: **10200408**  
Test Kit Date Tested for Accuracy: **02-28-2024**  
Test Kit Mfr. & Mod. #: **Mid-West 845-5 (Potable)**  
Testing Co Name: **L Sinclair Services Inc.**  
Phone: **(512) 563-8762**  
Address: **1307 Machado Road  
Cedar Park, TX 78613**

The above tester certifies that all information submitted for this report is true and accurate  
\* TEST RECORDS MUST BE KEPT FOR AT LEAST THREE YEARS [30 TAC §290.46(B)]  
\*\* USE ONLY MANUFACTURER'S REPLACEMENT PARTS

The backflow prevention assembly detailed above has been tested and maintained as required by commission regulations and is certified to be operating within acceptable parameters