



4050 FM 1660 Hutto, Texas 78634 512-759-1286 Fax 512-759-2983

**BACKFLOW PREVENTION ASSEMBLY TEST AND MAINTENANCE REPORT**

PWS I.D: **2460022**

MAILING ADDRESS 2000 Vanderside Rd. Hutto, TX 78634

CONTACT PERSON Taylor Morrison

LOCATION OF SERVICE 2000 Vanderside Rd. Hutto, TX 78634

INSPECTION DATE 9/20/2024 12:55PM

The backflow prevention assembly detailed below has been tested and maintained as required by TCEQ regulations and is certified to be operating within acceptable parameters.

**TYPE OF ASSEMBLY**

- |  |  |
|--|--|
| <input type="checkbox"/> Reduced Pressure ZONE         | <input type="checkbox"/> Reduced Pressure Principle-Detector     |
| <input checked="" type="checkbox"/> Double Check Valve | <input type="checkbox"/> Double Check-Detector                   |
| <input type="checkbox"/> Pressure Vacuum Breaker       | <input type="checkbox"/> Spill-Resistant Pressure Vacuum Breaker |

Manufacturer: Apollo \_\_\_\_\_

Model # DC4A \_\_\_\_\_ Serial # 01688D \_\_\_\_\_

Location of device Left front yard 5 feet from meter

Is the assembly installed in accordance with manufacturer recommendations and/or local codes? Yes \_\_\_\_\_

	Reduced Pressure Principle Assembly			Pressure Vacuum Breaker		
	Double Check Valve Assembly		Relief Valve	Air Inlet		Check Valve
	1st Check	2nd Check		Opened at	psid	
Initial Test	Held at 1.9 Psi	Held at 1.7 psid	Opened at	psid	Did not Open <input type="checkbox"/>	Leaked <input type="checkbox"/>
	Closed Tight <input checked="" type="checkbox"/> Leaked <input type="checkbox"/>	Closed <input checked="" type="checkbox"/> Tight <input type="checkbox"/> Leaked <input type="checkbox"/>	Did not open	<input type="checkbox"/>		
Repairs and Materials Used						
Test After Repair	Held at <input type="checkbox"/> psid Closed Tight <input type="checkbox"/>	Held at <input type="checkbox"/> psid Closed Tight <input type="checkbox"/>	Opened at	psid	Opened at	psid

The above is certified to be true at the time of testing,

Test gauge used: Make / Model Mid West 845 SN: 09231317 Calibration Date:3/14/2024

Firm Name Safewater Backflow Certified Tester: Brad Weyant

Firm Address PO Box 4002 Austin, TX 78765 Cert. Tester No: BP0016935

Firm Phone # 512-605-9790

**- TEST RECORDS MUST BE KEPT FOR AT LEAST THREE YEARS \*\* USE ONLY MANUFACTURER'S REPLACEMENT PARTS**