



4050 FM 1660 Hutto, Texas 78634 512-759-1286 Fax 512-759-2983

BACKFLOW PREVENTION ASSEMBLY TEST AND MAINTENANCE REPORT

PWS I.D: 2460022

MAILING ADDRESS 2002 Vanderscile Rd, Hutto, TX 78634

CONTACT PERSON Taylor Morrison Homes

LOCATION OF SERVICE 2002 Vanderscile Rd, Hutto, TX 78634

INSPECTION DATE 08/16/2024 2:41 pm

The backflow prevention assembly detailed below has been tested and maintained as required by TCEQ regulations and is certified to be operating within acceptable parameters.

TYPE OF ASSEMBLY

- Reduced Pressure ZONE
- Double Check Valve
- Pressure Vacuum Breaker
- Reduced Pressure Principle-Detector
- Double Check-Detector
- Spill-Resistant Pressure Vacuum Breaker

Manufacturer: Apollo

Model # DC4A Serial # 88921C

Location of device : Front Right at the meter

Is the assembly installed in accordance with manufacturer recommendations and/or local codes? YES

	Reduced Pressure Principle Assembly				Pressure Vacuum Breaker	
	Double Check Valve Assembly		Relief Valve	Air Inlet		Check Valve
	1st Check	2nd Check		Opened at	psid	Held at
Initial Test	Held at 2.0 psid	Held at 1.8 psid	Opened at	psid	Did not Open <input type="checkbox"/>	Leaked <input type="checkbox"/>
	Closed Tight <input checked="" type="checkbox"/> Leaked <input type="checkbox"/>	Closed Tight <input checked="" type="checkbox"/> Leaked <input type="checkbox"/>	Did not open	<input type="checkbox"/>		
Repairs and Materials Used						
Test After Repair	Held at psid Closed Tight <input type="checkbox"/>	Held at psid Closed Tight <input type="checkbox"/>	Opened at	psid	Opened at	psid Held At psid

The above is certified to be true at the time of testing,

Test gauge used: Make / Model Bac Flo 5 SN: 06163433 Calibration Date: 10/11/2023

Firm Name Safety Plus Services, LLC
 102 Wonder World Dr #304-522
 Firm Address San Marcos, TX 78666

Certified Tester Scott Stevenson
 Cert. Tester No. BP0017507

Firm Phone # 512-300-9659

- TEST RECORDS MUST BE KEPT FOR AT LEAST THREE YEARS ** USE ONLY MANUFACTURER'S REPLACEMENT PARTS