

4050 FM 1660 Hutto, Texas 78634 2983 512-759-1286 Fax 512-759-

BACKELOW PREVENTION ASSEMBLY TEST AND MAINTENANCE REPORT

PWS I.D: 2460022	AFLOW PREVENTION					JKI		
-	_3004 Vanderscile Road I	•						
	Taylor Morrison		4					
	ICE 3004 Vanderscile						_	
INSPECTION DATE _	_10/24/2024_12:10PM_							
	ion assembly detailed bating within acceptable		d and maintain	ied as req	uired by TCE0	Q regula	tions and	
		TYPE OF A	ASSEMBLY					
() Reduce		() Reduced Pressure Principle-Detector						
* *	ble Check Valve	() Double Check-Detector						
() Pressu	ure Vacuum Breaker		() Spill-Resistant Pressure Vacuum Breaker					
Manufacture	er: Apollo							
Model # DC	4A	Serial # 94095	C					
Location of	device Right front yard	5 feet from meter						
Is the assembly instal	led in accordance with	manufacturer recomi	mendations and	d/or local	codes? Yes			
		Pressure Principle A					ıum Breake	r
	Double Check Valve	<u> </u>	· · ·		Air Inlet Check Valve			
	Double Check Valve	Double Gleck Valve Assembly		i teller valve		All liller Check Va		aive
	1st Check	2nd Check			Opened at	psid	Held at	psid
Initial Test	Held at 2.1 Psi	Held at 2.0 psid	Opened at	psid	Did not Open		Leaked	
	Closed Tight X Leaked □	Closed X Tight Leaked □	Did not open					
Repairs and Materials Used								
Test After	Held at psid Closed Tight □	Held at psid Closed Tight □	Opened at	psid	Opened at	psid	Held At	psid
 Repair								
The above is certifie	ed to be true at the time	e of testing,						
Test gauge used: M	lake / Model Mid West	845 SN: 092	231317	Calibrati	ion Date:3/14/	2024		
Firm Name Safewater Backflow			Certified Tester: Brad Weyant					
Firm Address PO E	Box 4002 Austin, TX 7	8765	Cert. Tes	ster No: E	3P0016935			
Firm Phone # 512	-605-9790							

- TEST RECORDS MUST BE KEPT FOR AT LEAST THREE YEARS ** USE ONLY MANUFACTURER'S REPLACEMENT PARTS