Service Address	Hazard/CCID: 42215 Backflow Prevention Assembly Test Report				
* Location: 312 Chaste Tree Drive San Marcos, TX 78666					
SAN MARCOS, T	X 78666	Meter#: Flooded, could not access LID/Service:		erial #: Check if Correc	oct Corrections 97878C
		Account #:	M		Apollo
Site Use: Hazard: Irrigation			M	lodel:	DC4A
Mailing Address			Ту	ype:	DCVA
312 Chaste Tree Drive				ize: ☑	1"
San Marcos, TX 78666 Orientation:					Horizontal
			Pt		
Teet Due No Later than					Irrigation - Low
Test Due No Later than: Existing					
Reduced Pressure Principle Assembly					
Double Check V				PVB/SVB	
	Check Valve #1	Check Valve #2	Relief Valve	Air Inlet	Check Valve
Initial Test Date 11/15/24	Leaked ☐ Closed Tight ☒	Leaked ☐ ☐ ☐ ☐ ☐ ☐ ☐ ☐ ☐ ☐ ☐ ☐ ☐ ☐ ☐ ☐ ☐ ☐ ☐	Did not open	Did not open Opened Fully Yes	Leakeu
Time <u>9:35AM</u> Pass ⊠ fail □	Held at 2.0 PSID	Held at 1.6 PSID	Opened at PSID	No U	Held at PSID
Repairs	Cleaned Rubber Kit				
Date	Rubber Kit				
Time	Replaced U				
Final Test Date	Closed Tight	Closed Tight		Opened Fully	
Time PassFail	Held at PSID	Held at PSID	Opened at PSID	Opened at PSID	Held at PSID
Air Gap	Date	Time	Diameter	Separation	Pass
Comments:					Yes No per Installation
					Exercised
l certify all information on this report is true & accurate, acknowledging that incomplete reports will not be accepted. Service Restored Service Restored					
Tester Brad Weyant Signature 2/ Line Pressure 47					
		Expire 12/3/2024 Phone 5126059790			er Reading Flooded
		Calibration Date 3/14/2024			Test Results
Company Safewater Backflow Phone 5126059790 Pass					Pass ⊠ Fail 🗌



Submit completed Test Report: 630 E HOPKINS ST

SAN MARCOS TX 78666 512-393-8008 Fax:

SODONNELL@SANMARCOSTX.GOV