

New Braunfels Utilities - Backflow Prevention Assembly Test and Maintenance Report

The following form must be completed for each assembly tested for recordkeeping *purposes:

New Braunfels Utilities
2356 Gruene Rd.
New Braunfels, Texas 78130

PWS ID: 0460001
Contact Name: James Garvin
Phone Number: 830-312-8098

BPAT Information

Company Name: Safewater Backflow and Irrigation
Tester Name: Brad Weyant
Address: 609 E 50TH
AUSTIN, Texas 78751

Phone Number: 5126059790
Email Address: brad@safewateratx.com
License Number: BP0016935
License Expiration: 12/3/2024

Location Information

Property Type: Residential
Business Name:
Property Address: 345 Hulda Trl
New Braunfels, TX 78130

Contact Information

Company Name:
Contact Name:
Mailing Address: 345 Hulda Trl
New Braunfels, TX 78130
Phone Number:
Email Address:

Backflow Information

The backflow prevention assembly detailed below has been tested and maintained as required by commission regulations and is certified to be operating within acceptable parameters.

Backflow Method: Double Check Valve
Main Assembly Manufacturer: Apollo **Model:** DC4A **Size:** 1 **Serial Number:** 88632C
Location: Right front yard 5 feet from meter
Hazard Type **:** Irrigation - Non Chemical

Backflow Test Information

Test Result: Passed
Reason for Test: New Installation

Is the assembly installed in accordance with manufacturers recommendations and/or local codes? Yes

Is the assembly installed on a non-potable water supply (auxiliary)? No

Differential pressure gauge used: MidWest 845-5 (potable) **Serial Number:** 09231317 **Date Tested for Accuracy:** 3/14/2024

| | Double Check Valve | |
|-----------------------------------|---|---|
| | Check Valve #1 | Check Valve #2 |
| Initial Test | Held at 2 PSID | Held at 2.2 PSID |
| Date: 7/10/2024 | <input checked="" type="checkbox"/> ClosedTight | <input checked="" type="checkbox"/> ClosedTight |
| Time: 10:50 AM | <input type="checkbox"/> Leaked | <input type="checkbox"/> Leaked |
| Repairs and Materials Used | | |
| Repair Details | | |
| Test After Repairs | Held at 0 PSID | Held at 0 PSID |
| | <input type="checkbox"/> Closed Tight | <input type="checkbox"/> Closed Tight |

Remarks

The above is certified to be true at the time of testing.

* TEST RECORDS MUST BE KEPT FOR AT LEAST THREE YEARS [30 TAC 290.46(B)]

** USE ONLY MANUFACTURER'S REPLACEMENT PARTS

*** 2nd Check: Numeric reading required for double check valve only.

**** Indicates additional information not present on the standard TCEQ report