Irrigation in Texas is regulated by the Texas Commission on Environmental Quality (TCEQ) MC-235, P.O. Box 13087, Austin, Texas 78711-3087. TCEQ's website is: www.tceq.texas.gov

Recommended Run Times (minutes)

0	Spray - Shrub	12
0	Spray – Lawn	25
0	Rotor – Lawn	45
0	Drip - Lawn	45

Recommended Monthly Cycles

	(Water Days	;)	
0	January	3	
	February	3	
	March	4	
	April	4	
9	May	7	
0	June	9	
0	July	11	
0	August	11	
0	September	9	
0	October	6	
0	November	4	
0	December	3	

- Recommended Maintenance

 Backflow Test Annually

 Filter Check Annually for debris

 Heads Run system monthly checking for leaks or broken heads

 Valve Covers Trim grass to keep exposed

 Controller Seasonal update programming

 Winter Run system briefly every 2 weeks if system turned off

Legend

- X Backflow
- Controller
- **Control Valve**
- Spray Shrub
- Spray Lawn
- Rotor Lawn
- **Bubbler**
- **Drip Tubing**
- Main Line

COMPLETION ITEMS PROVIDED

- The manufacturer's manual for the controller.
- A seasonal watering schedule.
- A list of components that require maintenance and the recommended frequency of maintenance.
- A permanent sticker has been attached to the controller indicating the warranty period for the irrigation system and contact information.
- The corrected or re-drawn design plans indicating the actual installation and components of the system.
- Location and operation of the isolation valve.


This irrigation system has been installed in accordance with all applicable state and local laws, ordinances, rules, regulations or orders. I have tested the system and determined that it has been installed according to the irrigation plan and is properly adjusted for the most efficient application of water at this time.





11.5.2024

NOTE: ALL Piping shown is diagrammatic and NOT illustrating actual location.









PROJECT: 378 FIVE MILE CREEK WAY

LOT 8 BLOCK P

KYLE, TX 78640



BEST OF TEXAS LANDSCAPES LIBERTY HILL, TEXAS 78642

(512) 260-1430

www.bestoftexaslandscapes.com