Service Address	Hazard/CCID: 4	Hazard/CCID: 42215 Backflow Prevention Assembly Test Report				
* Location: 405 Quiet Oak Road San Marcos, TX 78666						
SAN MARCOS, TX	X 78666	Meter#: 96225660 LID/Service:	) Se	erial #: Check if Corr	rrect Corrections	
l		Account #:		anufacturari	Apollo	
Site Use: Hazard: Irrigation			Mo	odel:	DC4A	
Mailing Address			Ту	ype:	Z]DCVA	
405 Quiet Oak Road			Siz	ize:	<b>⊠</b> _1"	
San Marcos, TX 78666			Or	rientation:		
			Pr	rotootion:	Irrigation - Low	
Test Due No Later than:		moved Commercial C	Industrial Residentia	1	mestic Irrigation X Fire	
Reduced Pressure Principle Assembly						
Double Check V		ve Assembly		PVI	PVB/SVB	
	Check Valve #1	Check Valve #2	Relief Valve	Air Inlet	Check Valve	
Initial Test Date 10-11-2024	Leaked  Closed Tight	Leaked ☐ Closed Tight ☒	Did not open	Opened Fully Yes		
Time <u>11:30AM</u> Pass <b>⊠</b> fail □	Held at 1.7 PSID	Held at 2.1 PSID	Opened at PSID	No D		
Repairs  Date  Time	Cleaned Rubber Kit Rebuild Replaced Other					
Final Test  Date	Closed Tight	Closed Tight		Opened Fully		
Time Pass ☐Fail ☐	Held at PSID	Held at PSID	Opened atPSID	Opened at PSID	Held at PSID	
Air Gap	Date	Time	Diameter	Separation	Pass	
Comments:				Pro	oper Installation Yes No	
I certify all information on this report is true & accurate, acknowledging that incomplete reports will not be accepted.					/ Exercised	
Tester Brad Weyant Signature						
BP0016935 Certification #		Expire 12/3/2024 Phone 5126059790			ne Pressure 6077.50	
·		Calibration Date 3/14/2024			Test Results	
Company Safewater Backflow Phone 5126059790					Pass ⊠ Fail □	



Submit completed Test Report: 630 E HOPKINS ST

SAN MARCOS TX 78666 512-393-8008 Fax: SODONNELL@SANMARCOSTX.GOV