

## New Braunfels Utilities - Backflow Prevention Assembly Test and Maintenance Report

The following form must be completed for each assembly tested for recordkeeping \*purposes:

New Braunfels Utilities  
 PO Box 310289  
 New Braunfels, Texas 78131

**PWS ID:** 0460001  
**Contact Name:** John Krause  
**Phone Number:** (830) 608-8812

### BPAT Information

**Company Name:** Safewater Backflow and Irrigation  
**Tester Name:** Brad Weyant  
**Address:** 609 E 50TH  
 AUSTIN, Texas 78751

**Phone Number:** 5126059790  
**Email Address:** brad@safewateratx.com  
**License Number:** BP0016935  
**License Expiration:** 12/3/2024

### Location Information

**Property Type:** Residential  
**Business Name:**  
**Property Address:** 407 Nash Dr  
 New, TX 78132

### Contact Information

**Company Name:**  
**Contact Name:**  
**Mailing Address:** 407 Nash Dr  
 New Braunfels, TX 78132  
**Phone Number:**  
**Email Address:**

### Backflow Information

The backflow prevention assembly detailed below has been tested and maintained as required by commission regulations and is certified to be operating within acceptable parameters.

**Backflow Method:** Double Check Valve  
**Main Assembly Manufacturer:** Apollo      **Model:** DC4A      **Size:** 1      **Serial Number:** 01547D  
**Location:** Left front yard 5 feet from meter  
**Hazard Type \*\*\*\*:** Irrigation - Non Chemical

### Backflow Test Information

**Test Result:** Passed  
**Reason for Test:** New Installation

**Is the assembly installed in accordance with manufacturers recommendations and/or local codes?** Yes

**Is the assembly installed on a non-potable water supply (auxiliary)?** No

**Differential pressure gauge used:** MidWest 845-5 (potable)      **Serial Number:** 09231317      **Date Tested for Accuracy:** 3/14/2024

	Double Check Valve	
	Check Valve #1	Check Valve #2
<b>Initial Test</b> Date: 10/8/2024 Time: 11:50 AM	Held at 0 PSID <input type="checkbox"/> ClosedTight <input checked="" type="checkbox"/> Leaked	Held at 0 PSID <input type="checkbox"/> ClosedTight <input checked="" type="checkbox"/> Leaked
<b>Repairs and Materials Used</b>	Cleaned	Cleaned
<b>Repair Details</b>	Repair Details - Check Valve #1: Flushed Rocks  Repair Details - Check Valve #2: Flushed Rocks	
<b>Test After Repairs</b> Date: 10/8/2024 Time: 11:55 AM	Held at 1.9 PSID <input checked="" type="checkbox"/> Closed Tight	Held at 2 PSID <input checked="" type="checkbox"/> Closed Tight

### Additional Information Required by New Braunfels Utilities \*\*\*\*

**Water Meter Number:**

### Remarks

The above is certified to be true at the time of testing.

\* TEST RECORDS MUST BE KEPT FOR AT LEAST THREE YEARS [30 TAC 290.46(B)]

\*\* USE ONLY MANUFACTURER'S REPLACEMENT PARTS

\*\*\* 2nd Check: Numeric reading required for double check valve only.

\*\*\*\* Indicates additional information not present on the standard TCEQ report