



4050 FM 1660 Hutto, Texas 78634 512-759-1286 Fax 512-759-2983

**BACKFLOW PREVENTION ASSEMBLY TEST AND MAINTENANCE REPORT**

PWS I.D: **2460022**

MAILING ADDRESS 412 Doodle Ln. Hutto, TX 78634 \_\_\_\_\_

CONTACT PERSON Taylor Morrison \_\_\_\_\_

LOCATION OF SERVICE 412 Doodle Ln. Hutto, TX 78634 \_\_\_\_\_

INSPECTION DATE 7/1/2024 11:40AM \_\_\_\_\_

The backflow prevention assembly detailed below has been tested and maintained as required by TCEQ regulations and is certified to be operating within acceptable parameters.

**TYPE OF ASSEMBLY**

- Reduced Pressure ZONE
- Double Check Valve
- Pressure Vacuum Breaker
- Reduced Pressure Principle-Detector
- Double Check-Detector
- Spill-Resistant Pressure Vacuum Breaker

Manufacturer: Apollo \_\_\_\_\_

Model # DC4A \_\_\_\_\_ Serial # 53123C \_\_\_\_\_

Location of device Right front yard 5 feet from meter \_\_\_\_\_

Is the assembly installed in accordance with manufacturer recommendations and/or local codes? Yes \_\_\_\_\_

	Reduced Pressure Principle Assembly			Pressure Vacuum Breaker		
	Double Check Valve Assembly		Relief Valve	Air Inlet		Check Valve
	1st Check	2nd Check		Opened at	psid	
Initial Test	Held at 2.3 Psi	Held at 2.2 psid	Opened at	psid	Did not Open <input type="checkbox"/>	Leaked <input type="checkbox"/>
	Closed Tight <input checked="" type="checkbox"/> Leaked <input type="checkbox"/>	Closed Tight <input checked="" type="checkbox"/> Leaked <input type="checkbox"/>	Did not open	<input type="checkbox"/>		
Repairs and Materials Used						
Test After Repair	Held at <input type="checkbox"/> Closed Tight	Held at <input type="checkbox"/> Closed Tight	Opened at	psid	Opened at	psid

The above is certified to be true at the time of testing,

Test gauge used: Make / Model Mid West 845 SN: 09231317 Calibration Date:3/14/2024

Firm Name Safewater Backflow Certified Tester: Brad Weyant

Firm Address PO Box 4002 Austin, TX 78765 Cert. Tester No: BP0016935

Firm Phone # 512-605-9790

**- TEST RECORDS MUST BE KEPT FOR AT LEAST THREE YEARS \*\* USE ONLY MANUFACTURER'S REPLACEMENT PARTS**