

## New Braunfels Utilities - Backflow Prevention Assembly Test and Maintenance Report

The following form must be completed for each assembly tested for recordkeeping \*purposes:

New Braunfels Utilities  
 PO Box 310289  
 New Braunfels, Texas 78131

**PWS ID:** 0460001  
**Contact Name:** John Krause  
**Phone Number:** (830) 608-8812

### BPAT Information

**Company Name:** Safety Plus Services, LLC.  
**Tester Name:** Scott Stevenson  
**Address:** 102 Wonder World Drive, Suite #304-522  
 San Marcos, Texas 78666

**Phone Number:** 512-300-9659  
**Email Address:** scott@safetyplusservices.com  
**License Number:** BP0017507  
**License Expiration:** 12/19/2025

### Location Information

**Property Type:** Residential  
**Business Name:**  
**Property Address:** 5768 Ryder Rd  
 New Braunfels, TX 78130

### Contact Information

**Company Name:** Highland Homes  
**Contact Name:**  
**Mailing Address:** 5768 Ryder Rd  
 New Braunfels, TX 78130  
**Phone Number:**  
**Email Address:**

### Backflow Information

The backflow prevention assembly detailed below has been tested and maintained as required by commission regulations and is certified to be operating within acceptable parameters.

**Backflow Method:** Double Check Valve  
**Main Assembly Manufacturer:** Apollo      **Model:** DC4A      **Size:** 1      **Serial Number:** 85350C  
**Location:** Front left - 7' from the meter  
**Hazard Type \*\*\*\*:** Irrigation - Non Chemical

### Backflow Test Information

**Test Result:** Passed  
**Reason for Test:** New Installation

**Is the assembly installed in accordance with manufacturers recommendations and/or local codes?** Yes

**Is the assembly installed on a non-potable water supply (auxiliary)?** No

**Differential pressure gauge used:** BacFlo Unlimited Bac Flo 5 (potable)      **Serial Number:** 06163433      **Date Tested for Accuracy:** 10/11/2023

	Double Check Valve	
	Check Valve #1	Check Valve #2
<b>Initial Test</b> Date: 9/4/2024 Time: 2:17 PM	Held at 1.8 PSID <input checked="" type="checkbox"/> ClosedTight <input type="checkbox"/> Leaked	Held at 1.8 PSID <input checked="" type="checkbox"/> ClosedTight <input type="checkbox"/> Leaked
<b>Repairs and Materials Used</b>		
<b>Repair Details</b>		
<b>Test After Repairs</b>	Held at 0 PSID <input type="checkbox"/> Closed Tight	Held at 0 PSID <input type="checkbox"/> Closed Tight

### Remarks

The above is certified to be true at the time of testing.  
 \* TEST RECORDS MUST BE KEPT FOR AT LEAST THREE YEARS [30 TAC 290.46(B)]  
 \*\* USE ONLY MANUFACTURER'S REPLACEMENT PARTS  
 \*\*\* 2nd Check: Numeric reading required for double check valve only.  
 \*\*\*\* Indicates additional information not present on the standard TCEQ report