
City of Leander - PWSID #2460012

Backflow Prevention Assembly Test and Maintenance Report





PWS Contact Name: Jeff Tucker Customer / Property Name: Resident PWS Phone Number: (512) 528-2780 Contact Name: N/A Property Address: 605 Runnel Dr PWS Address: PO Box 319

> Leander, TX 78641-5706 Leander, TX, 78646

The backflow prevention assembly detailed below has been tested as required by TCEQ regulations and is certified to be operating within acceptable parameters.

Assembly Information

Model #: DC4A Type: DC Size: 1" Serial#: 88865C **BPA Serves:** Manufacturer: Apollo Irrigation

Location: 4' WNW of Water Meter

Reason for test: [] new [X] existing [] replaced.

Is the assembly installed in accordance with manufacturer recommendations and/or local codes? [X] yes [] no

Water supply: Potable

Assembly Test Information

| Initial Test (Time: 11:25 am) | |
|----------------------------------|-----------------------------------|
| Check Valve #1 : 2.0 | Check Valve #2 : 2.0 |
| (X) Closed Tight/Held () Leaked | (X) Closed Tight/Held () Leaked |
| Final Test | |
| Check Valve #1 : 2.0 | Check Valve #2 : 2.0 |
| (X) Closed Tight/Held () Leaked | (X) Closed Tight/Held () Leaked |

As the tester of record, I affirm this test as: Passed [X] Failed [] Repairs Made:** No

Additional comments or repairs made / materials (parts) used:

(no comments)

Tester Information

Tester Name: Sinclair, Lewis 02-12-2026 Tester License Expiration: Certification#: BP0002815 Test Kit Serial #: 10200408 Test Kit Date Tested for Accuracy: 02-28-2024

Test Kit Mfr. & Mod. #: Mid-West 845-5 (Potable) Testing Co Name: L Sinclair Services Inc.

Phone: (512) 563-8762

Address: 1307 Machado Road Cedar Park, TX 78613

The above tester certifies that all information submitted for this report is true and accurate

The backflow prevention assembly detailed above has been tested and maintained as required by commission regulations and is certified to be operating within acceptable parameters

Test Date: 2024-11-25

^{*} TEST RECORDS MUST BE KEPT FOR AT LEAST THREE YEARS [30 TAC §290.46(B)]

^{**} USE ONLY MANUFACTURER'S REPLACEMENT PARTS