Recommended Run Times (minutes)

- Spray Shrub
- Spray Lawn
- 25 Rotor - Lawn
- 45
- Drip Lawn
- 45

12

Recommended Monthly Cycles

- (Water Days)
 - January
- February 3
- March
- April
- May
- June
- July
- August
- September
- October 6
- November
- December

Recommended Maintenance Backflow – Test Annually

- Filter Check Annually for debris
- Heads Run system monthly checking for leaks or broken heads Valve Covers Trim grass to keep exposed
- Controller Seasonal update programming
- Winter Run system briefly every 2 weeks if system turned off

Legend

- Backflow X
- Controller
- Control Valve
- Spray Shrub
- Spray Lawn
- Rotor Lawn
- Bubbler
 - **Drip Tubing**
- Main Line

COMPLETION ITEMS PROVIDED

- The manufacturer's manual for the controller.
- A seasonal watering schedule.
- A list of components that require maintenance and the recommended frequency of maintenance.
- A permanent sticker has been attached to the controller indicating the warranty period for the irrigation system and contact information.
- The corrected or re-drawn design plans indicating the actual installation and components of the system.
- Location and operation of the isolation valve.





This irrigation system has been installed in accordance with all applicable state and local laws, ordinances, rules, regulations or orders. I have tested the system and determined that it has been installed according to the irrigation plan and is properly adjusted for the most efficient application of water at this time.

Best of Texas

Landscapes

Irrigation in Texas is regulated by the Texas Commission on Environmental Quality (TCEQ) MC-235, P.O. Box 13087, Austin, Texas 78711-3087. TCEQ's website is: www.tceq.texas.gov

10

20

1" = 20'

NOTE: ALL Piping shown is diagrammatic and NOT illustrating actual location.

CLARK A CAR 78610-QUI-69

6917 QUIET STREAM WAY BUDA, TX 78610

LOT 21 BLOCK H TURNERS CROSSING NORTH



6917 QUIET

STREAM WAY

IRRIGATION PLAN



BEST OF TEXAS LANDSCAPES LIBERTY HILL, TEXAS 78642

www.bestoftexaslandscapes.com