

## City of Kyle - Backflow Prevention Assembly Test and Maintenance Report

The following form must be completed for each assembly tested for recordkeeping \*purposes:

City of Kyle  
520 E RR 150  
Kyle, Texas 78640

**PWS ID:** 1050002  
**Contact Name:** Mickal Morrison  
**Phone Number:** 737-877-2927

### BPAT Information

<b>Company Name:</b> Safety Plus Services, LLC.	<b>Phone Number:</b> 512-300-9659
<b>Tester Name:</b> Scott Stevenson	<b>Email Address:</b> scott@safetyplusservices.com
<b>Address:</b> 102 Wonder World Drive, Suite #304-522 San Marcos, Texas 78666	<b>License Number:</b> BP0017507
	<b>License Expiration:</b> 12/19/2025

### Location Information

**Property Type:** Residential  
**Business Name:**  
**Property Address:** 806 Jackson River Loop  
Kyle, TX 78640

### Contact Information

**Company Name:**  
**Contact Name:**  
**Mailing Address:** 806 Jackson River Loop  
Kyle, TX 78640  
**Phone Number:**  
**Email Address:**

### Backflow Information

The backflow prevention assembly detailed below has been tested and maintained as required by commission regulations and is certified to be operating within acceptable parameters.

**Backflow Method:** Double Check Valve  
**Main Assembly Manufacturer:** Apollo      **Model:** DC4A      **Size:** 1      **Serial Number:** 88899C  
**Location:** At meter  
**Hazard Type \*\*\*\*:** Irrigation - Non Chemical

### Backflow Test Information

**Test Result:** Passed  
**Reason for Test:** New Installation

**Is the assembly installed in accordance with manufacturers recommendations and/or local codes?** Yes

**Is the assembly installed on a non-potable water supply (auxiliary)?** No

**Differential pressure gauge used:** BacFlo Unlimited Bac Flo 5 (potable)      **Serial Number:** 06163433      **Date Tested for Accuracy:** 10/11/2023

	Double Check Valve	
	Check Valve #1	Check Valve #2
<b>Initial Test</b> Date: 7/1/2024 Time: 12:14 PM	Held at 2.4 PSID <input checked="" type="checkbox"/> ClosedTight <input type="checkbox"/> Leaked	Held at 2.4 PSID <input checked="" type="checkbox"/> ClosedTight <input type="checkbox"/> Leaked
<b>Repairs and Materials Used</b>		
<b>Repair Details</b>		
<b>Test After Repairs</b>	Held at 0 PSID <input type="checkbox"/> Closed Tight	Held at 0 PSID <input type="checkbox"/> Closed Tight

### Remarks

The above is certified to be true at the time of testing.  
\* TEST RECORDS MUST BE KEPT FOR AT LEAST THREE YEARS [30 TAC 290.46(B)]  
\*\* USE ONLY MANUFACTURER'S REPLACEMENT PARTS  
\*\*\* 2nd Check: Numeric reading required for double check valve only.  
\*\*\*\* Indicates additional information not present on the standard TCEQ report